



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7315-1335:0100
CATEGORY:	7315 - POWER UNITS
LISTEE:	Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com
DESIGN:	Models AL300ULX, *AL300ULXJ, AL300ULM, AL400UL, AL400ULX, *AL400ULXJ, AL400ULM, AL400UL3X, AL600UL3X, AL1024ULM and AL1024ULX power supply units. Model AL400ULX is identical to Model AL400UL except for a larger enclosure. Models AL400ULM is basically an AL400ULX with a MOM5 multi-output power module also typical of Models AL1024ULM and AL1024ULX respectively. Models AL300ULX and AL300ULM are designed to charge sealed lead acid type rechargeable batteries. Models AL400UL3X and AL600UL3X employ the triple output module ALX3B. *Model AL300ULXJ is identical to Model AL300ULX except for a larger enclosure; model number may be followed by additional alpha suffix, indicating enclosure color (e.g. R=Red, G=Gray). *Model AL400ULXJ is identical to Model AL400ULX except for a larger enclosure; model number may be followed by additional alpha suffix, indicating enclosure color (e.g. R=Red, G=Gray). Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	115 VAC input, 12 or 24 VDC output
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the standby batteries must provide 24 hours standby power during power loss.
MARKING:	Listee's name, model number, electrical rating and UL label.
APPROVAL:	Listed as power supply units for use with separately listed compatible fire alarm control units to provide power for door holders, door strikes or similar devices.
NOTES:	Not suitable for fire alarm indicating devices.

Rev. 06-07-12 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/04/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division