

## VertiLine Isolated Series

**CCTV** Isolated Rack Mount Power Supplies

## Models Include:

## VertiLine8i

- 24VAC or 28VAC @ 8A
- Eight (8) fuse protected electronically isolated outputs

## VertiLine16i

- 24VAC or 28VAC @ 16A
- Sixteen (16) fuse protected electronically isolated outputs

## VertiLine8Di

- 24VAC or 28VAC @ 8A
- Eight (8) PTC protected electronically isolated outputs

### VertiLine16Di

- 24VAC or 28VAC @ 16A
- Sixteen (16) PTC protected electronically isolated outputs

# **Installation Guide**





Altronix® More than just power.™ Rev. 031808

Service Rep. Name: \_\_\_\_ Address:

#### Overview:

Altronix VertiLine AC Isolated CCTV Rack Mount Power Supplies provide 8 or 16 camera channels in a space saving 1U EIA 19" rack mount chassis which may be rack, wall or shelf mounted. The units feature individually selectable 24VAC and/or 28VAC power outputs.

### **Specifications:**

#### Input:

 Selectable 115VAC, 60Hz or 230VAC, 50/60Hz input.

#### **Output:**

- Eight (8) or sixteen (16) individually selectable 24VAC or 28VAC power outputs with OFF position.
- Maximum 1A per output.
- Individual electronically isolated outputs.
- Eight (8) or sixteen (16) power LED indicators.
- External automotive blade fuses or PTC protected outputs.
- Surge suppression.

#### Features:

- Illuminated power disconnect circuit breaker with manual reset.
- Removable terminal blocks with locking screw flange.
- Ease of installation saves time and eliminates costly labor.

#### Mechanical:

- Units can be rack, wall or shelf mounted.
- Modular 1U standard EIA 19" rack mount chassis
- Enclosure Dimensions (H x W x D approx.): 1.625" x 19.125" x 8.5" (41.3mm x 486mm x 216mm).

# Eight (8) and Sixteen (16) Output Rack Mount Configuration Reference Chart:

					utput tection	ut)			Current			
Altronix Model Number	Output Voltage (VAC)	Total Output Current (Power)	Number of Outputs	Fused	Class 2 Rated Power- Limited Auto-Resettable PTC	Current (max. per output)	Fuse Rating	PTC Rating	115VAC 60Hz Input Cu	230VAC 50/60Hz Input Current	Agency Listings	UL Listings and File Numbers
VertiLine8i	24VAC or 28VAC	8A	8	<b>✓</b>	-	1A	ЗА	-	2.5A	1.5A	c <b>UL</b> us	UL Listed for Commercial CCTV Equipment (UL 2044).
VertiLine8Di	24VAC or 28VAC	8A	8	_	<b>✓</b>	1A	_	2.5A		1.JA		
VertiLine16i	24VAC or 28VAC	16A	16	<b>√</b>	-	1A	3A	_	5A	2.5A		CUL Listed - CSA Standard C22.2 No.1-04,
VertiLine16Di	24VAC or 28VAC	16A	16	-	<b>✓</b>	1A	-	2.5A				Audio, Video and Similar Equipment.

WARNING: To reduce the risk of fire or electric shock, do not expose the unit to rain or moisture. This installation should be made by qualified service personnel and should conform to the National Electrical Code and all local codes.

#### Installation Instructions:

- Set the input voltage selector switch located on the left side of the VertiLine unit for 115VAC or 230VAC operation (Fig. 1c, pg. 4).
- 2. Attach mounting brackets to VertiLine unit for rack or wall mount installation (Figs. 4-5, pg. 7). Affix rubber pads to VertiLine for shelf installation (Fig. 6, pg. 7).
- 3. Secure the unit in a rack, mount unit to a wall or place unit on a shelf as desired (unit should be spaced at least 3" from any video monitors). When installing the unit in a rack, allow for one half of a U spacing above the unit for ventilation.
- 4. Plug the grounded AC line cord (included) into the IEC 320 connector of the VertiLine unit (Fig. 1f, pg. 4). Insert the plug end of the line cord into a grounded AC receptacle.
- 5. Set illuminated master power disconnect circuit breaker to the (ON) position (Fig. 3, pg. 6).
- 6. Select 24VAC or 28VAC power output for cameras 1-8 for VertiLine8i and VertiLine8Di or cameras 1-16 for VertiLine16i and VertiLine16Di with the corresponding voltage adjustment switches (Fig. 1b, pg. 4).
- Measure output voltage before connecting cameras. This helps avoiding potential damage.
  All terminals with common suffix (P) "1P, 2P ..." are the same polarity.
- 8. Set illuminated master power disconnect circuit breaker to the (OFF) position (Fig. 3, pg. 6).
- 9. Connect the power outputs of the terminals marked [1P & 1N] to the power inputs of camera 1 (Fig. 2, pg. 5). Repeat this step for each additional camera (Outputs 2-16). After wiring is completed, insert terminal block into the corresponding connector and secure by tightening the screws.
- 10. Upon completion of wiring, set illuminated master power disconnect circuit breaker to the ON (RESET) position (Fig. 3, pg. 6).
- 11. The power LEDs (Green) on the faceplate for Outputs 1-8 for VertiLine8i and VertiLine8Di or Outputs 1-16 for VertiLine16i and VertiLine16Di will illuminate when AC power is present (*Fig. 1a, pg. 4*). If all of the LEDs are OFF, there may be a complete loss of supply power to the VertiLine unit or the illuminated master power disconnect circuit breaker is in the OFF position.

#### To restore the power output for VertiLine8i or VertiLine16i:

- 1- Switch corresponding output voltage switch to the OFF position (Fig. 1b, pg. 4).
- 2- Eliminate the trouble condition.
- 3- Replace the corresponding automotive blade fuse.

#### Replace fuses with same type and rating:


Output fuses are rated @ 3A for all models.

4- Switch output voltage switch to the 24VAC or 28VAC position as desired (Fig. 1b, pg. 4).


#### To restore the power output for VertiLine8Di or VertiLine16Di:


- 1- Switch corresponding output voltage switch to the OFF position (Fig. 1b, pg. 4).
- 2- Eliminate the trouble condition.
- 3- Allow 1 minute for PTC to cool off.
- 4- Switch output voltage switch to the 24VAC or 28VAC position as desired (Fig. 1b, pg. 4).





The PTCs are located on the inside of the rack mount chassis.







The lightning flash with arrowhead symbol within an equilateral triangle is intended to alert the user to the presence of an insulated DANGEROUS VOLTAGE within the product's enclosure that may be of sufficient magnitude to constitute an electric shock.




The exclamation point within an equilateral triangle is intended to alert the user to the presence of important operating and maintenance (servicing) instructions in the literature accompanying the appliance.




**CAUTION:** To reduce the risk of electric shock do not open enclosure. There are no user serviceable parts inside. Refer servicing to qualified service personnel.

# 1U EIA 19" Rack Mount Chassis Mechanical Drawing & Dimensions (H $\times$ W $\times$ D):

1.625" x 19.125" x 8.5" (41.3mm x 486mm x 216mm)






(Fig. 3, pg. 6).

- 6 -

#### **Mounting Options:**


#### **Rack Mount Installation**

- 1. Remove factory installed screws from both sides of the rack chassis (Fig. 4a).
- 2. Install mounting brackets (A) on the left and right side of rack chassis using the two (2) flat head screws (B) (included) (Fig. 4b).
- 3. Place unit into desired EIA 19" rack position and secure with mounting screws (not included) (Fig. 4c).




#### **Wall Mount Installation**


- Install mounting brackets (A) on the left and right side of rack chassis using two (2) flat head screws (B) (included) (Fig. 5a).
- Place unit at desired location and secure with mounting screws (not included) (Fig. 5b).
  Caution: It is necessary to make sure mounting screws are securely fastened to a beam when installing.





- 1. Position and affix rubber pads (C) (included) at each corner on the bottom of the unit (Fig. 6).
- 2. Place unit in desired location.





#### **Notes:**

Altronix is not responsible for any typographical errors.

